

BIOTECH TESTING SERVICES

TEST REPORT

LAB NO. : 2002606/ 1

DATE: 04/08/2020

NAME OF CUSTOMER

: M/S KRUSHA ENTERPRISES LLP

ADDRESS

: Ground Floor, Shreeram Mansion, Prarthna Samaj, Mumbai 400004

REFERENCE

: Letter Ref. No.: Nil dated June 23, 2020

K. Attention: Mr. Kruti Adnani

DATE OF RECEIPT

: 30/07/2020

DATE OF INITIATION

: 30/07/2020

DATE OF COMPLETION

: 04/08/2020

SAMPLE DESCRIPTION

: MASK SAMPLE LABELED AS: -

Sr. No.	Description
1.	Virus Shield (SW) – Knitted fabric & SMMS filter by Tevero



Page 1 of 2

Samples are not drawn by the laboratory
 Result relate only to the samples tested
 This report shall not be reproduced except in full without prior permission of this laboratory



BIOTECH TESTING SERVICES

Name of Test:

Bacterial Filtration Efficiency (BFE) of Medical Face Mask Sample Materials, using a Biological Aerosol of Staphylococcus aureus by ASTM: F 2101 - 19

Test Organism Used:

Staphylococcus aureus - ATCC 6538

Inoculum Size:

2.00 x 108 CFU/ ml

Test Equipment:

Aerosol challenge Apparatus with Nebulizer assembly and Cascade impactor

Flow Rate of Cascade Impactor:

28.3 L / min

Aerosol Size:

3 microns ± 0.5

Procedure:

Test sample was clamped between cascade impactor and an aerosol chamber at a distance of 15 cms. Bacterial aerosol of bacteria – Staphylococcus aureus were generated in the chamber using the nebulizer assembly. Aerosols of test organisms of size 3 microns were drawn through the test material using a vacuum attached to cascade impactor. Positive control samples collected aerosol with no test specimen to determine the upstream aerosol counts. The ratio of upstream to down stream was reported as Percentage Bacterial Filtration efficiency. Following results are the Average of three readings.

Results:

Sample Identification	Average Bacterial count	BFE (Percentage) 98.66
Virus Shield (SW) – Knitted fabric & SMMS filter by Tevero	40	
Positive Control	3.00 x 10 ³	N. A.

INTERPRETATION:

Mask labeled as Virus Shield (SW) – Knitted fabric & SMMS filter by Tevero has exhibited 98.66% Bacterial Filtration Efficiency when analysed as per ASTM: F 2101 - 19 standard.



For BIOTECH TESTING SERVICES

Dr Shilpa U. Nair Quality Manager (Authorized Signatory)

> 2002606/1 Page 2 of 2

Samples are not drawn by the laboratory
 Result relate only to the samples tested
 This report shall not be reproduced except in full without prior permission of this laboratory

104/105, Malwa, Patanwala Ind. Estate, L.B.S. Marg, Ghatkopar (W), Mumbai - 400086, INDIA • Tel.: +91-22-2500 2811, 2500 2812 Email: info@biotechts.in / report@biotechts.in / biotechtestingservices@gmail.com / shilpanair@biotechts.in